

2806

RECEIVED

**From:** wilsonbear@TurboUSA.com  
**Sent:** Wednesday, January 06, 2010 1:06 PM  
**To:** EP, RegComments  
**Subject:** Chapter 95 regulations

2010 JAN -7 PM 2:39

INDEPENDENT REGULATORY  
REVIEW COMMISSION

Dear DEP Environmental Quality Board,

I am writing to comment on the proposed new Chapter 95 regulations. I support the three major effluent parameters announced by DEP in this regulation. The discharge may not contain more than 500 mg/L of TDS, no more than 250mg/L of total chlorides, and no more than 250 mg/L of total sulfates as a monthly average. In addition I feel that discharge standards for other contaminants often found in Marcellus shale wastewater such as bromides, arsenic, radium, and others should be added to these regulations.

And I believe that drilling in Marcellus shale formations should cease until water treatment facilities have the ability to process frack water to with in the parameters of these proposed new regulations. Thank you.

Sincerely yours,

Wilson T Bear  
740 Deering Run Rd.  
Austin, Pa. 16720